



Product Service

Attestation of Conformity

No. M8A 15 12 58692 020

Holder of Certificate: AR CO., LTD.

709 3DA Shihwa Complex, 1275-8
Jeongwang-Dong, Shiheung-Si, Gyeonggi-Do 429-450
REPUBLIC OF KOREAProduct: Air conditioning equipment
(Precision Air Conditioner Standard)Model(s): PA003-A1ST, PA005-A1ST, PA008-A1ST,
PA010-A1ST, PA015-A1ST, PA006-A2ST,
PA010-A2ST, PA015-A2ST, PA020-A2ST,
PA025-A2ST, PA030-A2ST, PA003-W1ST,
PA005-W1ST, PA008-W1ST, PA010-W1ST,
PA015-W1ST, PA006-W2ST, PA010-W2ST,
PA015-W2ST, PA020-W2ST, PA025-W2ST,
PA030-W2STParameters: Rated input voltage: 380-400 V a.c., 3 Phase
Rated frequency: 50/60 Hz
Rated input current: see the attachment
Cooling capacity: see the attachment
Reheating capacity: see the attachment
Humidification capacity: see the attachment
Refrigerant: R-22, R-407C
IP degree: IP43
Protection class: I
Weight: see the attachmentTested according to: EN ISO 12100:2010
EN 60204-1:2006/A1:2009
EN 378-1:2008/A2:2012
EN 378-2:2008/A2:2012
EN 378-3:2008/A1:2012
EN 378-4:2008/A1:2012

This Attestation of Conformity is issued on a voluntary basis according to Council Directive 2006/42/EC relating to machinery. It confirms that the listed equipment (not Annex IV equipment) complies with the principal protection requirements of the directive. It refers only to the sample submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: MAEB01057115

Date, 2015-12-02 (Yong-Sam Choi)



After preparation of the necessary technical documentation as well as the EC declaration of conformity the required CE marking can be affixed on the product. Other relevant directives have to be observed.



Page 1 of 3